

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

7 / 22 / 10

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 32 So Union St Unit # _____

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: WM GV3

Location of Heating System: _____

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) David Lachance

Licensure for plumbing & heating?
 Yes No License #: Pm 4084

Certification for gas equipment?
 Yes No Cert #: GN 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David R. Sullivan

Comments: TAG # 10431

C1251.3
Benoure P+H

TEST 43
DATE 07/22/10
TIME 15:21:26

COMBUSTION

FUEL	NAT	GAS
O2 %		3.1
CO2 %		10.1
CO ppm		18
FLUE °F		147.1
INLT °F		77.2
NETT °F		69.9
EFF (G)		88.5
LOSSES		11.5
XAIR %		17.4
CO/CO2	0.0001	
CO AIR FREE	21	
PRS hPA		-0.02

Customer

Appliance

Ref

Benoure Plumbing & Heating, Inc.