

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:
7, 22, 10

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 34 So Union St Unit # _____

Heating System(s) Type:
(Check all that Apply)
Space Heater
Warm Air Furnace
Wall Mount Furnace
 Boiler
Gas Fireplace
Other

Fuel Type:
 Natural Gas
Oil
Propane

Venting System(s):
(Check all that Apply)
 Direct Vent
B-Vent
Masonry *
Other

*All masonry chimneys lined or unlined
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Wm 6V3

Location of Heating System: _____

System Passed System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) David Lachance

Licensure for plumbing & heating?
 Yes No License #: Pm 4084

Certification for gas equipment?
 Yes No Cert #: 6N 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David Lachance

Comments: TAB # 10432

0125 1.3
Benoure P+H

TEST 44
DATE 07/22/10
TIME 15:32:59

COMBUSTION		
FUEL	NAT	GAS
O2 %		3.5
CO2 %		9.9
CO PPM		15
FLUE %F		110.5
INLT %F		75.3
NETT %F		35.2
EFF (G)		89.3
LOSSES		10.7
XAIR %		20.1
CO/CO2	0.0001	
CO AIR FREE	18	
PRS	hPA	0.01

.....
Customer
.....
Appliance
.....
Ref: