

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

7, 21, 10

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards  
Address of Inspected Unit: 355 Pearl Unit # 2

### Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

### Fuel Type:

- Natural Gas
- Oil
- Propane

### Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined  
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Wm 6V4  
Location of Heating System: \_\_\_\_\_

System Passed      System Failed      If System Failed, Next Appt: \_\_\_/\_\_\_/\_\_\_

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
(Please Print) David R. Lachance

Licensure for plumbing & heating?  
 Yes      No License #: Pm 4084

Certification for gas equipment?  
 Yes      No Cert #: GN 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David Johnson

Comments: Tag # 10180

C12-1-3  
Benoure P+H

TEST      31  
DATE      07/21/10  
TIME      01:58:01

### COMBUSTION

FUEL	NAT	GAS
O2 %		4.0
CO2 %		9.6
CO PPM		11
FLUE °F	152.8	
INLT °F	91.3	
NETT °F	61.5	

EFF (G)      88.6  
LOSSES      11.4  
XAIR %      23.7

CO/CO2      0.0001  
CO AIR FREE      13

PRS hPA      0.00

Gene Richards  
Customer  
355 Pearl # 2  
Appliance

Ref. \_\_\_\_\_