

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

7 / 21 / 10

Heating and Venting System Documentation FormName of Owner of Inspected Unit: Gene RichardsAddress of Inspected Unit: 355 Pearl StUnit # 3**Heating System(s) Type:**

(Check all that Apply)

Space Heater
Warm Air Furnace
Wall Mount Furnace
☒ Boiler
Gas Fireplace
Other

Fuel Type:

☒ Natural Gas
Oil
Propane

Venting System(s):

(Check all that Apply)

☒ Direct Vent
B-Vent
Masonry *
Other

* All masonry chimneys lined or unlined

need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: WM 6V4

Location of Heating System: _____

☒ System Passed

System Failed

If System Failed, Next Appt: ____/____/____

Company Conduction Inspection:

Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:

(Please Print)

David P. Jackson

Licensure for plumbing & heating?

☒ Yes No License #: PM 4084

Certification for gas equipment?

Yes No Cert #: GN 2057

I have inspected the heating and venting system (s) and
certify that it is/they are installed properly and is/are
operating safely at this time.

Signature of
Inspector:David P. JacksonComments: TA6# 10421C 12
Benoure P+H

TEST 32
DATE 07/21/10
TIME 02:01:43

COMBUSTION

FUEL NAT GAS

O2 % 2.4
CO2 % 10.5
CO PPM 21
FLUE °F 145.1
INLT °F 91.3
NETT °F 53.8

EFF (G) 88.9
LOSSES 11.1
XAIR % 13.0

CO/CO2 0.0002
CO AIR FREE 23

PRS hPA 0.01

Gene Richards

Customer
355 Pearl St
Appliance

Ref. _____