

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
 S. Burlington, VT 05403  
 Phone 802-864-7156  
 Fax 802-864-7167

Date of Inspection:  
7, 21, 10

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards  
 Address of Inspected Unit: 355 Pearl St Unit # 6

**Heating System(s) Type:**  
 (Check all that Apply)

Space Heater  
 Warm Air Furnace  
 Wall Mount Furnace  
 Boiler  
 Gas Fireplace  
 Other

**Fuel Type:**

Natural Gas  
 Oil  
 Propane

**Venting System(s):**  
 (Check all that Apply)

Direct Vent  
 B-Vent  
 Masonry \*  
 Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: WM GV4  
 Location of Heating System: \_\_\_\_\_

System Passed     
  System Failed     
 If System Failed, Next Appt:   /  /  

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
 (Please Print) David P. Lachance

Licensure for plumbing & heating?

Yes     
 No License #: Pm 4084

Certification for gas equipment?

Yes     
 No Cert #: 6N2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David P. Lachance

Comments: TAG # 10422

\_\_\_\_\_

\_\_\_\_\_

C - - -  
 Benoure P+H

TEST            33  
 DATE            07/21/10  
 TIME            02:10:08

COMBUSTION

FUEL	NAT	GAS
O2 %		3.0
CO2 %		10.2
CO ppm		18
FLUE °F		140.6
INLT °F		85.7
NETT °F		54.9
EFF (G)		88.9
LOSSES		11.1
XAIR %		16.8
CO/CO2	0.0001	
CO AIR FREE		21
PRS	hpa	0.00

Gene Richards  
 Customer  
355 Pearl #6  
 Appliance

Ref. \_\_\_\_\_