

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:  
7, 23, 10

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 361 Pearl St Unit # 2

**Heating System(s) Type:**  
*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
*(Check all that Apply)*

- Direct Vent
- B-Vent
- Masonry \*
- Other

*\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: Wm Ultra 80  
Location of Heating System: \_\_\_\_\_

System Passed      System Failed      If System Failed, Next Appt:   /  /  

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
*(Please Print)* David Lachance

Licensure for plumbing & heating?  
 Yes      No License #: Rm 4084

Certification for gas equipment?  
 Yes      No Cert #: 6W 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David B. Lachance

Comments: TAG # 10438

**C125**  
Benoure P+H

TEST            50  
DATE            07/23/10  
TIME            12:34:07

**COMBUSTION**

FUEL	NAT	GAS
O2 %		5.8
CO2 %		8.6
CO PPM		12
FLUE °F	138.3	
INLT °F	86.6	
NETT °F	51.7	

EFF (G)	88.7
LOSSES	11.3
XAIR %	38.4

CO/CO2            0.0001  
CO AIR FREE        16

PRS    hPA            0.03

.....  
Customer

.....  
Appliance

.....  
Ref.

.....