

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

7, 23, 10

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 361 Pearl Unit # 3

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: Wm Ultra 80

Location of Heating System: _____

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) David LaChance

Licensure for plumbing & heating?
 Yes No License #: Pm 4084

Certification for gas equipment?
 Yes No Cert #: GN 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David G. Johnson

Comments: TAG # 10439

CIF
BENOURE PTH

TEST 51
DATE 07/23/10
TIME 12:37:14

COMBUSTION

FUEL	NAT	GAS
O2 %		5.1
CO2 %		9.0
CO PPM		15
FLUE °F	141.1	
INLT °F	86.6	
NETT °F	54.5	
EFF (G)	88.7	
LOSSES	11.3	
XAIR %	32.3	
CO/CO2	0.0001	
CO AIR FREE	19	
PRS hPA	0.05	

.....
Customer
.....
Appliance
.....
Ref.
.....

Benoure Plumbing & Heating, Inc.