

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

7, 23, 10

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards  
Address of Inspected Unit: 361 Pearl St Unit # 5

**Heating System(s) Type:**  
*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
*(Check all that Apply)*

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: WM ULTRA 80  
Location of Heating System: \_\_\_\_\_

System Passed     System Failed    If System Failed, Next Appt:     /    /    

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
*(Please Print)* David LaChance

Licensure for plumbing & heating?  
 Yes     No License #: PM 4084

Certification for gas equipment?  
 Yes     No Cert #: GN 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David LaChance

Comments: TAG # 10561

Certification Tag #: 10561

**C 12**  
Benoure P+H

TEST                    53  
DATE                    07/23/10  
TIME                    12:40:19

**COMBUSTION**

FUEL	NAT	GAS
O2 %		5.6
CO2 %		8.7
CO PPM		16
FLUE °F		140.2
INLT °F		86.6
NETT °F		53.6

EFF (G)                    88.7  
LOSSES                    11.3  
XAIR %                    36.6

CO/CO2                    0.0001  
CO AIR FREE              21  
PRS hPA                    0.08

Customer  
Appliance  
Ref:                    ...  
.....