

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

7, 23, 10

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 361 Pearl St Unit # 6

**Heating System(s) Type:**  
*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
*(Check all that Apply)*

- Direct Vent
- B-Vent
- Masonry \*
- Other

\* All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: WM Ultra 80

Location of Heating System: \_\_\_\_\_

System Passed     System Failed    If System Failed, Next Appt: 1/1

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
*(Please Print)* David Kachene

Licensure for plumbing & heating?  
 Yes     No License #: Pr 4084

Certification for gas equipment?  
 Yes     No Cert #: GW 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David Kachene

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Certification Tag #: 10562

1 - 3  
Benoure P+H

TEST                    54  
DATE                    07/23/10  
TIME                    12:41:59

**COMBUSTION**  
.....

FUEL	NAT	GAS
O2 %		5.0
CO2 %		9.0
CO ppm		17
FLUE °F		132.5
INLT °F		86.6
NETT °F		45.9

EFF (G)                    88.9  
LOSSES                    11.1  
XAIR %                    31.4

CO/CO2                    0.0001  
CO AIR FREE                22

PRS    hPA                0.08

.....  
Customer

.....  
Appliance

Re                    .....

.....