

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

7, 23, 10

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards  
Address of Inspected Unit: 361 Pearl St Unit # 7

**Heating System(s) Type:**  
*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
*(Check all that Apply)*

- Direct Vent
- B-Vent
- Masonry \*
- Other

\* All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: WM Ultra 80  
Location of Heating System: \_\_\_\_\_

System Passed     System Failed    If System Failed, Next Appt: 1/1/11

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
*(Please Print)* David Lechner

Licensure for plumbing & heating?  
 Yes     No License #: Pm 4084

Certification for gas equipment?  
 Yes     No Cert #: GN 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David Lechner

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Certification Tag #: 10563

1 - 3  
Benoure P+H

---

TEST                    55  
DATE                    07/23/10  
TIME                    12:43:24

COMBUSTION

FUEL	NAT	GAS
O2 %		5.6
CO2 %		8.7
CO PPM		15
FLUE %F		144.4
INLT %F		86.6
NETT %F		57.8
EFF (G)		88.5
LOSSES		11.5
XAIR %		36.6
CO/CO2	0.0001	
CO AIR FREE	20	
PRS hPA	0.09	

.....  
Customer  
.....  
Appliance  
.....  
Ref.  
.....