

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:
7, 23, 10

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 361 Pearl St Unit # 8

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: WM ULTRA 80

Location of Heating System: _____

System Passed System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) David Jackson

Licensure for plumbing & heating?
 Yes No License #: PM 4084

Certification for gas equipment?
 Yes No Cert #: 6N 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David Jackson

Comments: TAG # 10564

TEST 56
DATE 07/23/10
TIME 12:43:55

COMBUSTION

FUEL	NAT	GAS
O2 %		5.6
CO2 %		8.7
CO PPM		13
FLUE %F		143.8
INLT %F		86.6
NETT %F		57.2

EFF (G) 88.6
LOSSES 11.4
XAIR % 36.6

CO/CO2 0.0001
CO AIR FREE 17
PRS hPA 0.09

.....
Customer
.....
Appliance
.....
.....
.....