

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

7, 26, 10

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards
Address of Inspected Unit: 452 S. Union Unit # 1

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Am. Std Aux D80C942D3
Location of Heating System: _____

System Passed System Failed If System Failed, Next Appt: 1/1

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) David Luchance

Licensure for plumbing & heating?
 Yes No License #: Pm 4084

Certification for gas equipment?
 Yes No Cert #: GN 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David Luchance

Comments: _____

Certification Tag #: 56 10565

1 - 3
C.C. e P+H

TEST 57
DATE 07/26/10
TIME 09:02:08

COMBUSTION
.....

FUEL	NAT	GAS
O2 %		10.5
CO2 %		5.9
CO PPM		10
FLUE °F		111.6
INLT °F		67.7
NETT °F		43.9

EFF (G) 88.5
LOSSES 11.5
XAIR % 101.0

CO/CO2 0.0001
CO AIR FREE 20

PRS hPA 0.01

Customer: #1
Appliance: _____

RE: _____
.....