

Benoure Plumbing & Heating, Inc.

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

7, 26, 10

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards  
Address of Inspected Unit: 457 S. Union St Unit # 2

**Heating System(s) Type:**  
*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
*(Check all that Apply)*

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Am Std Aux 10 DC 948 D 7  
Location of Heating System: Basement

System Passed     System Failed    If System Failed, Next Appt: 1/1

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
*(Please Print)* David LaChance

Licensure for plumbing & heating?  
 Yes     No License #: PM 4084

Certification for gas equipment?  
 Yes     No Cert #: GN 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David LaChance

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Certification Tag #: 10567

**C125 1-3**  
Benoure P+H

TEST                    58  
DATE                    07/26/10  
TIME                    09:07:58

**COMBUSTION**

FUEL	NAT	GAS
O2 %		8.6
CO2 %		7.0
CO ppm		17
FLUE %F		114.3
INLT %F		67.7
NETT %F		47.2
EFF (G)		88.6
LOSSES		11.4
XAIR %		69.9
CO/CO2	0.0002	
CO AIR FREE	28	
PRS	hPA	0.04

.....  
tomer .....  
.....  
iance .....  
.....  
.....