

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:  
7, 26, 10

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards  
Address of Inspected Unit: 452 S. Union St Unit # 3

- Heating System(s) Type:**  
*(Check all that Apply)*
- Space Heater
  - Warm Air Furnace
  - Wall Mount Furnace
  - Boiler
  - Gas Fireplace
  - Other

- Fuel Type:**
- Natural Gas
  - Oil
  - Propane

- Venting System(s):**  
*(Check all that Apply)*
- Direct Vent
  - B-Vent
  - Masonry \*
  - Other
- \*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Am Std  
Location of Heating System: \_\_\_\_\_

System Passed     System Failed    If System Failed, Next Appt:   /  /  

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Certification Tag #: 12566

Person Conducting Inspection:  
*(Please Print)* David Johnson

Licensure for plumbing & heating?  
 Yes     No License #: Pm 4084

Certification for gas equipment?  
 Yes     No Cert #: 612057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David Johnson

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

1 - 3  
Pressure P+H

---

TEST                    59  
DATE                    07/26/10  
TIME                    09:11:11

COMBUSTION  
.....

FUEL	NAT	GAS
O2 %		10.5
CO2 %		5.9
CO ppm		13
FLUE °F		113.6
INLT °F		67.7
NETT °F		45.9
EFF (G)		88.4
LOSSES		11.6
XAIR %		101.0
CO/CO2	0.0002	
CO AIR FREE		26
PRS hPA		0.04

Customer .....  
.....  
.....  
.....  
.....