

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:
7 / 22 / 10

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 58 Buell St Unit # 1

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Wm GV6

Location of Heating System: _____

System Passed System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) David LaChance

Licensure for plumbing & heating?
 Yes No License #: Pm 4084

Certification for gas equipment?
 Yes No Cert #: GN 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David B. LaChance

Comments: Tag 10425

IC125 1.3
Benoure P+H

TEST 36
DATE 07/21/10
TIME 23:12:16

COMBUSTION

| FUEL | NAT | GAS |
|-------------|--------|-------|
| O2 % | | 5.5 |
| CO2 % | | 8.8 |
| CO PPM | | 06 |
| FLUE °F | | 128.9 |
| INLT °F | | 74.2 |
| NETT °F | | 54.7 |
| EFF (G) | | 88.7 |
| LOSSES | | 11.3 |
| XAIR % | | 35.7 |
| CO/CO2 | 0.0000 | |
| CO AIR FREE | 08 | |
| PRS | hPA | 0.01 |

.....
Customer

.....
Appliance
58 Buell # 1
.....
Ref.