

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

7 / 22 / 10

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 58 Buell St # 2 Unit # 2

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: WM CGS 4

Location of Heating System: _____

System Passed

System Failed

If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:

(Please Print)

David P. Lachance

Licensure for plumbing & heating?

Yes No License #: Pm 4084

Certification for gas equipment?

Yes No Cert #: 6N 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David P. Lachance

Comments: TAB # 10426

C125
Benoure P+H

TEST 37
DATE 07/21/10
TIME 23:18:50

COMBUSTION

FUEL	NAT	GAS
O2 %		8.6
CO2 %		7.0
CO PPM		23
FLUE °F		142.8
INLT °F		74.2
NETT °F		68.6

EFF (G)	87.9
LOSSES	12.1
XAIR %	69.9

CO/CO2	0.0003
CO AIR FREE	39

PRS hPA	0.03
---------	------

Customer

Appliance

58 Buell #2

Ref.

Benoure Plumbing & Heating, Inc.