

Benoure Plumbing & Heating, Inc.

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:
7 / 22 / 10

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 58 Buell St Unit # 3

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined
 need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Wm CGS 4

Location of Heating System: _____

System Passed System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print)
David P. LaChonco

Licensure for plumbing & heating?
 Yes No License #: Pm 4084

Certification for gas equipment?
 Yes No Cert #: 6N 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David P. LaChonco

Comments: TA6 10427

C 125
 Benoure P+H

TEST 38
 DATE 07/21/10
 TIME 23:20:35

COMBUSTION

FUEL	NAT	GAS
O2 %		9.3
CO2 %		6.6
CO PPM		17
FLUE °F	126.7	
INLT °F	74.2	
NETT °F	52.5	

EFF (G) 88.4
 LOSSES 11.6
 XAIR % 80.2

CO/CO2 0.0002
 CO AIR FREE 30

PRS hPA 0.04

.....
 Customer

.....
 Appliance
58 Buell #3
 Ref.
