

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

7 / 22 / 10

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards  
 Address of Inspected Unit: 70 Buell Unit # 1ST FL

**Heating System(s) Type:**  
*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
*(Check all that Apply)*

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Olsen 6TH 85  
 Location of Heating System: Basement

System Passed       System Failed      If System Failed, Next Appt:     /     /    

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
*(Please Print)* David Wallace

Licensure for plumbing & heating?  
 Yes      No License #: Pm 4084

Certification for gas equipment?  
 Yes      No Cert #: 6N 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David P. Johnson

Comments: TAG 10 428

**C125**  
Benoure P+H

TEST                      40  
 DATE                      07/21/10  
 TIME                      23:57:20

**COMBUSTION**

FUEL	NAT	GAS
O2 %		9.5
CO2 %		6.5
CO ppm		17
FLUE °F		92.2
INLT °F		72.6
NETT °F		19.6

EFF (G)	89.5
LOSSES	10.5
XAIR %	83.3

CO/CO2                      0.0002  
 CO AIR FREE                      31

PRS    hPA                      0.00

Richards  
 Customer  
70 Buell 1st  
 Appliance

Ref.                      .....