

# Benoure Plumbing & Heating, Inc.

34 Commerce Avenue  
 S. Burlington, VT 05403  
 Phone 802-864-7156  
 Fax 802-864-7167

Date of Inspection:

7, 22, 10

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 72 Buell St Unit # 2nd Fl

**Heating System(s) Type:**

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Am Std Aux 1 B080A9421AB

Location of Heating System: Basement

System Passed       System Failed      If System Failed, Next Appt:   /  /  

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
 (Please Print) David P. LoChance

Licensure for plumbing & heating?  
 Yes      No License #: Pm 4084

Certification for gas equipment?  
 Yes      No Cert #: GN 2057

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: David P. LoChance

Comments: TAG 10429

**C125**  
 Benoure P+H

TEST                      39  
 DATE                      07/21/10  
 TIME                      23:53:54

**COMBUSTION**

FUEL	NAT	GAS
O2 %		11.0
CO2 %		5.6
CO PPM		17
FLUE °F		99.6
INLT °F		72.7
NETT °F		26.9

EFF (G)	89.1
LOSSES	10.9
XAIR %	111.1

CO/CO2                      0.0003  
 CO AIR FREE                      35

PRS    hPA                      0.00

.....  
 Customer Richards

.....  
 Appliance 72 Buell St 2nd

.....  
 Ref.   

Benoure Plumbing & Heating, Inc.