

Benoure Plumbing & Heating, Inc. TAG # 10221

**34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167**

Date of Inspection:
8 / 18 / 2010

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Address of Inspected Unit: 202 Howard Unit # 8

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: CVM EGS-4-PIN

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print)
Dan Crossman


Licensure for plumbing & heating?

Yes License #: PM-3945

Certification for gas equipment?

Yes Cert #: GN-2081

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: 

Comments: _____

C125 1.3

TEST 45

DATE 08/17/10

TIME 12:57:57

CAF

COMBUSTION		
FUEL	NAT	GAS
O2 %		9.0
CO2 %		6.8
CO PPM		31
FLUE °F		240.3
INLT °F		75.6
NETT °F		164.7
EFF (G)		84.6
LOSSES		15.4
XAIR %		75.6
CO/CO2	0.0004	
CO AIR FREE	54	
PRS	hPa	0.00

Customer: _____

Appliance: _____

Ref.: _____