

Benoure Plumbing & Heating, Inc. IAG # 10723

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:
8 / 18 / 2010

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments / Gene Richards

Address of Inspected Unit: 202 Howard Unit # 3

Heating System(s) Type:
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- ~~Boiler~~
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined
 need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: LWM CGS-4-PIN

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
 (Please Print)
 Dan Crossman


Licensure for plumbing & heating?

Yes License # :PM-3945

Certification for gas equipment?

Yes Cert #: GN-2081

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: 

Comments: _____

C125 1.3

TEST 48
 DATE 08/17/10
 TIME 13:07:13

C

COMBUSTION		
FUEL		NAT	GAS
O2 %			8.1
CO2 %			7.3
CO PPM			30
FLUE	°F		273.7
INLT	°F		75.6
NETT	°F		204.1
EFF (G)			83.7
LOSSES			16.3
XAIR %			63.3
CO/CO2		0.0004	
CO AIR FREE		48	
PRS	hPA	0.02	

.....
 Customer

.....
 Appliance

.....
 Ref.

.....