

Benoure Plumbing & Heating, Inc. IAG # 10704

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:
8 / 18 / 2010

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments / Gene Richards

Address of Inspected Unit: 355 Pearl St Unit # 10

Heating System(s) Type:
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
 (Check all that Apply)

- Direct Vent
 - B-Vent
 - Masonry *
 - Other
- *All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Prestige Excellence 110
 Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: / /


Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
 (Please Print)
 Dan Crossman

Licensure for plumbing & heating?
 Yes License # :PM-3945

Certification for gas equipment?
 Yes Cert #: GN-2081

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: 

Comments: _____

benoure.....
 #.25.....



BACHARACH, INC.
 Fyrite Insight
 SN: PX1278

Time: 02:04:17 PM
 Date: 08/18/10

Fuel
 Nat Gas

O ₂	4.1 %
CO	44 ppm
Eff	92.9 %
CO ₂	9.5 %
T-STK	119 °F
T-AIR	84.2 °F
EA	21.5 %
CO(O)	55 ppm

Comments: _____