

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:
 8 / 18/2010

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments / Gene Richards

Address of Inspected Unit: 355 Pearl St Unit # 7

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Bostwick V

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
 (Please Print)
 Dan Crossman

Licensure for plumbing & heating?

Yes License #: PM-3945

Certification for gas equipment?

Yes Cert #: GN-2081

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: 

Comments: _____

benoure.....
 #.25.....



BACHARACH, INC.
 Fyrite Insight
 SN: PX1278

Time: 01:42:28 PM
 Date: 08/18/10

Fuel
 Nat Gas

| | |
|-----------------|---------|
| O ₂ | 2.1 % |
| CO | 28 ppm |
| EFF | 88.7 % |
| CO ₂ | 10.6 % |
| T-STK | 166 °F |
| T-AIR | 78.3 °F |
| EA | 9.8 % |
| CO(O) | 31 ppm |

Comments: _____