

**Benoure Plumbing & Heating, Inc. TAG #** 10706

**34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167**

Date of Inspection:  
8 / 18 / 2010

**Heating and Venting System Documentation Form**

Name of Owner of Inspected Unit: Champlain Apartments / Gene Richards

Address of Inspected Unit: 355 Pearl St Unit # 8

**Heating System(s) Type:**  
*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler**
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
*(Check all that Apply)*

- Direct Vent**
- B-Vent
- Masonry \*
- Other

*\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: Prestige Excellence 110

Location of Heating System: Basement

System Passed

System Failed

If System Failed, Next Appt:     /     /    

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
*(Please Print)*  
Dan Crossman


Licensure for plumbing & heating?

Yes License #: PM-3945

Certification for gas equipment?

Yes Cert #: GN-2081

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: 

Comments: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

benoure:.....  
#.25.....  
.....



BACHARACH, INC.  
Fyrite Insight  
SN: PX1278

Time: 02:21:01 PM  
Date: 08/18/10

Fuel  
Nat Gas

O <sub>2</sub>	4.0 %
CO	46 ppm
Eff	89.6 %
CO <sub>2</sub>	9.5 %
T-STK	136 °F
T-AIR	86.9 °F
EA	21.3 %
CO (0)	57 ppm

Comments: \_\_\_\_\_