

LIFE SAFETY SYSTEMS, INC.®

P.O. Box 76, Essex Jct., VT 05453-0076



PHONE 802-879-5355

FAX 802-879-4574

IN VERMONT 1-800-649-9995

FIRE ALARM SYSTEM
Test & Inspection Report
VERMONT PROOF OF INSPECTION STICKER # 10-04940
SYSTEM IDENTIFICATION # F-18123

Customer: Richards Apartments – 361 Pearl Street

Date: June 25, 2010

Contact: Gene Richards

Location: 361 Pearl Street, Burlington

Time: Start: 11:20 End: 12:40 Total: 1:20

Techs Sent: MC, ML

Panel Make & Model: Silent Knight 5208

Date Installed: June 2007

	(Ah)	AC Line	DC Charge Rate	Battery Voltage Under Load	
				DC Starting	DC Ending
Power Supply	12	121.8	27.3	27.0	25.4
Manual Pull Stations	Qty: 7		# Zones: 4	Tested: 7	
Signal Horn/Strobes	Qty: 5		# Zones: 1	Tested: 5	
Signal Horn/Strobes WP	Qty: 2		# Zones: 1	Tested: 2	
Horns Only	Qty: 12		# Zones: 4	Tested: 12	
Automatic Detection					
Photoelectric Smokes	Qty: 5		# Zones: 4	Tested: 5	
Sprinkler Tamper	Qty: 2		# Zones: 1	Tested: 2	
Sprinkler Flow	Qty: 1		# Zones: 1	Tested: 1	
AC/DC CO Smokes	Qty: 49		# Zones: NA	Tested: 49	
System CO Detector	Qty: 1		# Zones: 1	Tested: 1	

Auxiliary Features

None


Deficiencies Found


- 1) Apt #2 – AC/DC CO smoke detector in living room failed

Action Taken

- 1) None

Comments: 1) Front exit door Apt #3 is Exit of Convenience and has no pull station. 2) Batteries due for replacement June 2011.


Authorized Representative
VT State License #T1-1377


Reviewed by # T1-1059

cc: VT Department of Public Safety - Williston
Burlington Fire Department - Burlington