

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.

TRG # 12402

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:
4 / 15 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 18 N. Union St Unit # 1

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: W/m CGS-4

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryan

Licensure for plumbing & heating?
 Yes No License #: PS-163

Certification for gas equipment?
 Yes No Cert #: GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: _____

benoure.....
#.25.....
.....



BACHARACH, INC.
Fyrite Insight
SN: PX1278

Time: 12:08:36 PM
Date: 04/15/11

Fuel
Nat Gas

O ₂	8.8 %
CO	19 ppm
Eff	84.6 %
CO ₂	6.8 %
T-SIK	241 °F
T-AIR	62.3 °F
EA	65.0 %
CO (0)	32 ppm

Comments:

Benoure Plumbing & Heating, Inc. Tag # 12404

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:
4 / 15 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 18 N. Union St Unit # 2

Heating System(s) Type:
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

* All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: W/m CGS-4

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryan

Licensure for plumbing & heating?
 Yes No License #: PS-163

Certification for gas equipment?
 Yes No Cert #: CB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: _____

benoure.....
#.25.....
.....



BACHARACH, INC.
Fyrite Insight
SN: PX1278

Time: 12:07:52 PM
Date: 04/15/11

Fuel
Nat Gas

O ₂	8.5 %
CO	23 ppm
Eff	84.7 %
CO ₂	7.0 %
T-STK	243 °F
T-AIR	62.3 °F
EA	60.7 %
CO(O)	39 ppm

Comments: _____

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc. TAG# 13106

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:
4 / 15 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards
Address of Inspected Unit: 20 N. Union St. Unit # 1

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Wlm CGS-4
Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryan

Licensure for plumbing & heating?
Yes No License #: PS-163

Certification for gas equipment?
Yes No Cert #: GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: _____

benoure.....
#.25.....
.....



BACHARACH, INC.
Fyrite Insight
SN: PX1278

Time: 12:05:51 PM
Date: 04/15/11

Fuel
Nat Gas

O ₂	12.0 %
CO	14 ppm
Eff	84.1 %
CO ₂	5.0 %
T-STK	210 °F
T-AIR	61.5 °F
EA	119.2 %
CO(O)	32 ppm

Comments: _____

Benoure Plumbing & Heating, Inc. TAG# 13105

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:
4 / 15 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 20 N. Union Unit # 2

Heating System(s) Type:
 (Check all that Apply)
 Space Heater
 Warm Air Furnace
 Wall Mount Furnace
 Boiler
 Gas Fireplace
 Other

Fuel Type:
 Natural Gas
 Oil
 Propane

Venting System(s):
 (Check all that Apply)
 Direct Vent
 B-Vent
 Masonry *
 Other
 *All masonry chimneys lined or unlined
 need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: W/m CGS-4

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
 (Please Print) Jeff Ryan

Licensure for plumbing & heating?
 Yes No License #: PS-163


Certification for gas equipment?
 Yes No Cert #: GB-448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: _____

benoure.....
 #.25.....



Time: 12:04:58 PM
 Date: 04/15/11

Fuel
 Nat Gas

O ₂	9.7 %
CO	20 ppm
Eff	85.1 %
CO ₂	6.3 %
T-STK	215 °F
T-AIR	61.2 °F
EA	76.5 %
CO(O)	37 ppm

Comments: _____