

Benoure Plumbing & Heating, Inc. TAG# 13147

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

4 / 13 / 11

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Jene RichardsAddress of Inspected Unit: 21 Hungerford St Unit #

## Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

## Fuel Type:

- Natural Gas
- Oil
- Propane

## Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\* All masonry chimneys lined or unlined  
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Triangle Tube Prestige Solo 175Location of Heating System: Basement System Passed System FailedIf System Failed, Next Appt: / /

Company Conduction Inspection:

Benoure Plumbing &amp; Heating, Inc.

Person Conducting Inspection:

(Please Print)

Tim Tom Slog

Licensure for plumbing &amp; heating?

Yes

No License #:

Certification for gas equipment?

Yes

No Cert #: GB-1996

I have inspected the heating and venting system (s) and  
certify that it is/they are installed properly and is/are  
operating safely at this time.

Signature of  
Inspector: ESL

Comments:

benoure.....  
#.25.....  
.....



BACHARACH, INC.  
Fyrite Insight  
SN: PX1278

Time: 10:24:58 AM  
Date: 04/13/11

Fuel  
Nat Gas

O <sub>2</sub>	4.8 %
CO	25 ppm
Eff	97.0 %
CO <sub>2</sub>	9.1 %
T-STK	99 °F
T-AIR	55.3 °F
EA	26.9 %
CO (0)	33 ppm

Comments: