

Benoure Plumbing & Heating, Inc. TAG# 13155

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:

4 / 14 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 286 Pearl St Unit # 1

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined
 need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Travis Industries 3403565572

Location of Heating System: Living room in apt #1

System Passed

System Failed

If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:

(Please Print)

Tim Trumbley

Licensure for plumbing & heating?

Yes No License #: _____

Certification for gas equipment?

Yes No Cert #: GB 1996

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: _____

Comments: Room air Test

Gas Fireplace vented
Through roof

benoure.....
 #.25.....



BACHARACH, INC.
 Fyrite Insight
 SN: PX1278

Time: 10:52:05 AM
 Date: 04/14/11

Fuel
 Nat Gas

O ₂	20.9 %
CO	0 ppm
Eff	--- %
CO ₂	--- %
T-SIK	77 °F
T-AIR	48.5 °F
EA	--- %
CO(O)	--- ppm

Comments: _____

Benoure Plumbing & Heating, Inc. TAG# 13120

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:

4 / 14 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 286 Pearl St Unit # 2

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Heat N Glo SL-550TRSC

Location of Heating System: Living room in Apt #2

System Passed

System Failed

If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:

(Please Print)

Tim Tombley

Licensure for plumbing & heating?

Yes No License #: _____

Certification for gas equipment?

Yes No Cert #: GB 1996

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: [Signature]

Comments: Room Air Test

benoure..... |
 #.25..... |
 |



BACHARACH, INC.
 Fyrite Insight
 SN: PX1278

Time: 11:08:01 AM
 Date: 04/14/11

Fuel
 Nat Gas

O ₂	20.9 %
CO	0 ppm
Eff	--- %
CO ₂	--- %
T-S1K	76 °F
T-AIR	56.6 °F
EA	--- %
CO(O)	--- ppm

Comments:

1

Benoure Plumbing & Heating, Inc. TAG# 13119

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

4 / 14 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richard
Address of Inspected Unit: 286 Peck St Unit # 3

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: TRAVI Bed + Breakfast

Location of Heating System: _____

System Passed

System Failed

If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:

(Please Print)

Tim Tomblay

Licensure for plumbing & heating?

Yes No License #: _____

Certification for gas equipment?

Yes No Cert #: GB 1996

I have inspected the heating and venting system (s) and
certify that it is/they are installed properly and is/are
operating safely at this time.

Signature of
Inspector: [Signature]

Comments: Room Air Test

benoure.....
#.25.....
.....



BACHARACH, INC.
Fyrite Insight
SN: PX1278

Time: 11:19:46 AM

Date: 04/14/11

Fuel
Nat Gas

O ₂	20.9 %
CO	0 ppm
Eff	--- %
CO ₂	--- %
T-STK	85 %
T-ATR	
EA	
...	