

Benoure Plumbing & Heating, Inc. TAG# 13156

34 Commerce Avenue
S. Burlington, VT 05403
Phone 802-864-7156
Fax 802-864-7167

Date of Inspection:

4 / 14 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 302 Colchester Ave

Unit # _____

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Weil me claim GR-4

Location of Heating System: Basement

System Passed

System Failed

If System Failed, Next Appt: ___/___/___

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
(Please Print) Jeff Ryan

Licensure for plumbing & heating?

Yes No License #: PS-163

Certification for gas equipment?

Yes No Cert #: GB 448

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: _____

benoure.....
#.25.....
.....



BACHARACH, INC.
Fyrite Insight
SN: PX1278

Time: 12:06:49 PM
Date: 04/14/11

Fuel
Nat Gas

O ₂	3.3 %
CO	15 ppm
EFF	87.3 %
CO ₂	9.9 %
T-STK	200 °F
T-AIR	60.6 °F
EA	16.9 %
CO(O)	18 ppm

Comments: _____

Benoure Plumbing & Heating, Inc.