

**Benoure Plumbing & Heating, Inc. TAG#** 13145

34 Commerce Avenue  
 S. Burlington, VT 05403  
 Phone 802-864-7156  
 Fax 802-864-7167

Date of Inspection:

4 / 13 / 11

**Heating and Venting System Documentation Form**

Name of Owner of Inspected Unit: GENE Richards

Address of Inspected Unit: 32 S UNION Unit # \_\_\_\_\_

**Heating System(s) Type:**  
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined  
 need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Wm GV-3

Location of Heating System: Basement

System Passed

System Failed

If System Failed, Next Appt:     /    /    

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
 (Please Print) Tom Tomster / Jeff R...


Licensure for plumbing & heating?  
 Yes      No License #: \_\_\_\_\_

Certification for gas equipment?  
 Yes      No Cert #: GB 448

I have inspected the heating and venting system (s) and  
 certify that it is/they are installed properly and is/are  
 operating safely at this time.

Signature of Inspector: [Signature]

Comments: [Signature]

benoure.....  
 # 25.....  
  
 BACHARACH, INC.  
 Fyrite Insight  
 SN: PX1278

Time: 09:34:24 AM  
 Date: 04/13/11

	Fuel
	Nat Gas
O <sub>2</sub>	2.8 %
CO	18 ppm
EIF	87.7 %
CO <sub>2</sub>	10.2 %
T-SIK	177 °F
T-AIR	50.9 °F
EA	14.0 %
CO(O)	21 ppm

Comments: \_\_\_\_\_

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc. TAG# ~~14132~~ 13/46

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:  
4 / 13 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 34 S Union St Unit # \_\_\_\_\_

Heating System(s) Type:  
*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):  
*(Check all that Apply)*

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined  
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: WM GV-3

Location of Heating System: \_\_\_\_\_

System Passed System Failed If System Failed, Next Appt: \_\_\_/\_\_\_/\_\_\_

Company Conduction Inspection:  
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:  
*(Please Print)*  
Tim Towler

Licensure for plumbing & heating?  
Yes No License #: \_\_\_\_\_

Certification for gas equipment?  
Yes No Cert #: GB 1996

I have inspected the heating and venting system (s) and  
certify that it is/they are installed properly and is/are  
operating safely at this time.

Signature of Inspector: [Signature]

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

benoure.....  
#.25.....  
.....



BACHARACH, INC.  
Fyrite Insight  
SN: PX1278

Time: 09:54:09 AM  
Date: 04/13/11

Fuel  
Nat Gas

O <sub>2</sub>	3.8 %
CO	13 ppm
EFF	87.8 %
CO <sub>2</sub>	9.7 %
T-SIK	170 °F
T-AIR	54.4 °F
EA	19.5 %
CO(0)	15 ppm

Comments: \_\_\_\_\_  
\_\_\_\_\_