

# Benoure Plumbing & Heating, Inc. TAG# 13481

34 Commerce Avenue  
 S. Burlington, VT 05403  
 Phone 802-864-7156  
 Fax 802-864-7167

Date of Inspection:

7 / 13 / 11

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 325 College St. Unit # 1

Heating System(s) Type:  
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

- Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):  
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Prestige Excellence 110

Location of Heating System: Basement

System Passed

System Failed

If System Failed, Next Appt:     /    /    

Company Conduction Inspection:  
 Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:  
 (Please Print)

Ryan Benoure

Licensure for plumbing & heating?

Yes

No License #: PM-4086


Certification for gas equipment?

Yes

No Cert #: GN-2938

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector:



Comments:

**C125 1-3**  
 Benoure P+H

TEST 08  
 DATE 07/13/11  
 TIME 08:48:00

COMBUSTION

FUEL	NAT	GAS
O2 %		5.4
CO2 %		8.8
CO PPM		22
FLUE °F	151.6	
INLT °F	75.4	
NETT °F	76.2	

EFF (G) 88.0  
 LOSSES 12.0  
 XAIR % 34.8

CO/CO2 0.0002  
 CO AIR FREE 29

PRS hPA 0.00

Gene Richards  
 Customer

PE110  
 Appliance

325 College St #1  
 Ref.

Benoure Plumbing & Heating, Inc.

# Benoure Plumbing & Heating, Inc. TAG# 13482

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:

7 / 13 / 11

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 325 College St.

Unit # 2

Heating System(s) Type:  
*(Check all that Apply)*

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):  
*(Check all that Apply)*

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Prestige Excellence 110

Location of Heating System: Basement

System Passed

System Failed

If System Failed, Next Appt:      /      /     

Company Conduction Inspection:  
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:  
*(Please Print)*

Ryan Benoure

Licensure for plumbing & heating?

Yes No License #: PM-4086

Certification for gas equipment?

Yes No Cert #: GN-2938

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: [Signature]

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

125 1-3  
Benoure P+H

TEST 89  
DATE 07/13/11  
TIME 08:52:07

### COMBUSTION

FUEL	NAT	GAS
O2 %		5.1
CO2 %		9.0
CO ppm		26
FLUE % F		155.4
INLT % F		75.4
NETT % F		80.0

EFF (G) 88.0  
LOSSES 12.0  
XAIR % 32.3

CO/CO2 0.0002  
CO AIR FREE 34

PRS hPA 0.01

Gene Richards  
Customer  
PE110  
Appliance  
325 College #2  
Ref.

**Benoure Plumbing & Heating, Inc. TAG# 13483**

34 Commerce Avenue  
 S. Burlington, VT 05403  
 Phone 802-864-7156  
 Fax 802-864-7167

Date of Inspection:  
7 / 13 / 11

**Heating and Venting System Documentation Form**

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 325 College St Unit # 3

**Heating System(s) Type:**  
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Prestige Excellence 110

Location of Heating System: Basement

System Passed

System Failed

If System Failed, Next Appt:     /    /    

Company-Conduction-Inspection:  
 Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:  
 (Please Print)

Ryan Benoure

Licensure for plumbing & heating?

Yes

No License #: PM-4086

Certification for gas equipment?

Yes

No Cert #: GN-2938

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of

Inspector: [Signature]

Comments:

C125 1-3  
 Benoure P+H

TEST 10  
 DATE 07/13/11  
 TIME 09:23:36

COMBUSTION

FUEL	NAT	GAS
O2 %		5.0
CO2 %		9.0
CO PPM		23
FLUE °F		155.5
INLT °F		76.0
NETT °F		79.5

EFF (G) 88.0  
 LOSSES 12.0  
 XAIR % 31.4

CO/CO2 0.0003  
 CO AIR FREE 38  
 PRS hPA 0.00

Gene Richards.....  
 Customer  
PE110.....  
 Appliance  
325 College #3.....  
 Ref.

**Benoure Plumbing & Heating, Inc. TAG# 13484**

34 Commerce Avenue  
 S. Burlington, VT 05403  
 Phone 802-864-7156  
 Fax 802-864-7167

Date of Inspection:

7 / 13 / 11

**Heating and Venting System Documentation Form**

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 325 College St.

Unit # 4

**Heating System(s) Type:**  
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Prestige Excellence 110

Location of Heating System: Basement

System Passed

System Failed

If System Failed, Next Appt: \_\_\_/\_\_\_/\_\_\_

Company Conduction Inspection:  
**Benoure Plumbing & Heating, Inc.**

Person Conducting Inspection:  
 (Please Print) Ryan Benoure

Licensure for plumbing & heating?

Yes

No License #: PM-4086

Certification for gas equipment?

Yes

No Cert #: GN-2938

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: [Signature]

Comments: \_\_\_\_\_

**C125 1-3**  
 Benoure P+h

TEST 11  
 DATE 07/13/11  
 TIME 09:43:11

**COMBUSTION**

FUEL	NAT	GAS
O2 %		5.1
CO2 %		9.0
CO ppm		23
FLUE °F		172.6
INLT °F		73.5
NETT °F		99.1

EFF (G) 87.5  
 LOSSES 12.5  
 XAIR % 32.3

CO/CO2 0.0002  
 CO AIR FREE 30

PRS hPA 0.04

..Gene Richards...  
 Customer  
 ..PE110...  
 Appliance  
 ..325 College #4...  
 Ref.

Benoure Plumbing & Heating, Inc.

**Benoure Plumbing & Heating, Inc. TAG# 13485**

34 Commerce Avenue  
 S. Burlington, VT 05403  
 Phone 802-864-7156  
 Fax 802-864-7167

Date of Inspection:

7 / 13 / 11

**Heating and Venting System Documentation Form**

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 325 College St. Unit # 5

**Heating System(s) Type:**  
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Prestige Excellence 110

Location of Heating System: Basement

System Passed

System Failed

If System Failed, Next Appt: \_\_\_/\_\_\_/\_\_\_

Company Conduction Inspection:  
 Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:  
 (Please Print) Ryan Benoure

Licensure for plumbing & heating?

Yes

No License #: PM-4086

Certification for gas equipment?

Yes

No Cert #: GN-2438

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: [Signature]

Comments: \_\_\_\_\_

C125 1.3  
 Benoure P+H

TEST 12  
 DATE 07/13/11  
 TIME 09:51:42

COMBUSTION

FUEL	NAT	GAS
O2 %		5.6
CO2 %		8.7
CO PPM		17
FLUE °F		165.8
INLT °F		73.5
NETT °F		92.3
EFF (G)		87.6
LOSSES		12.4
XAIR %		36.6
CO/CO2	0.0001	
CO AIR FREE	23	
PRS hPA	0.04	

Gene Richards  
 Customer  
PE110  
 Appliance  
325 College #5  
 Ref.

Benoure Plumbing & Heating, Inc.

# Benoure Plumbing & Heating, Inc. TAG# 13486

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:  
7 / 13 / 11

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 325 College St. Unit # 6

**Heating System(s) Type:**  
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Prestige Excellence 110

Location of Heating System: Basement

System Passed    System Failed    If System Failed, Next Appt:     /    /    


Company Conduction Inspection:  
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:  
(Please Print) Ryan Benoure

Licensure for plumbing & heating?  
 Yes    No License #: PM-4086

Certification for gas equipment?  
 Yes    No Cert #: GN-2938

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: 

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

C125 1.3  
Benoure P+H

TEST 13  
DATE 07/13/11  
TIME 10:08:15

COMBUSTION

FUEL	NAT	GAS
O2 %		5.2
CO2 %		8.9
CO PPM		26
FLUE °F		155.3
INLT °F		78.3
NETT °F		79.0

EFF (G) 88.0  
LOSSES 12.0  
XAIR % 33.1

CO/CO2 0.0002  
CO AIR FREE 34  
PRS hPA 0.00

Gene Richards  
Customer  
PE110  
Appliance  
325 College St #6  
Ref.

Benoure Plumbing & Heating, Inc.

# Benoure Plumbing & Heating, Inc. TAG# 13487

34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

Date of Inspection:  
7 / 13 / 11

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 325 College St. Unit # 7

**Heating System(s) Type:**  
(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Prestige Excellence

Location of Heating System: Basement

System Passed

System Failed

If System Failed, Next Appt:      /      /     

Company Conduction Inspection:  
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:  
(Please Print) Ryan Benoure

Licensure for plumbing & heating?  
 Yes No License #: PM-4086

Certification for gas equipment?  
 Yes No Cert #: GN-2938

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: [Signature]

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

C125 1.3  
Benoure P+H

TEST 14  
DATE 07/13/11  
TIME 10:20:59

COMBUSTION

FUEL	NAT	GAS
O2 %		4.6
CO2 %		9.2
CO PPM		32
FLUE °F		158.4
INLT °F		76.9
NETT °F		81.5
EFF (G)		88.0
LOSSES		12.0
XAIR %		29.8
CO/CO2	0.0003	
CO AIR FREE		41
PRS hPA		0.00

Gene Richards  
Customer  
PE 110  
Appliance  
325 College # 7  
Ret.

# Benoure Plumbing & Heating, Inc. TAG# 13488

34 Commerce Avenue  
 S. Burlington, VT 05403  
 Phone 802-864-7156  
 Fax 802-864-7167

Date of Inspection:

7 / 13 / 11

## Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 325 College St. Unit # 8

Heating System(s) Type:  
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):  
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined  
 need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Prestige Excellence 110

Location of Heating System: Basement

System Passed

System Failed

If System Failed, Next Appt:     /    /    

Company Conduction Inspection:  
 Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:  
 (Please Print) Ryan Benoure

Licensure for plumbing & heating?

Yes

No License #: PM-4086

Certification for gas equipment?

Yes

No Cert #: GN-2938

I have inspected the heating and venting system (s) and  
 certify that it is/they are installed properly and is/are  
 operating safely at this time.

Signature of Inspector: [Signature]

Comments: \_\_\_\_\_

C125 1.3  
 Benoure P+H

TEST 15  
 DATE 07/13/11  
 TIME 10:30:39

COMBUSTION

FUEL	NAT	GAS
O2 %		5.1
CO2 %		9.0
CO PPM		25
FLUE °F		150.9
INLT °F		74.9
NETT °F		74.0
EFF (G)		88.2
LOSSES		11.8
XAIR %		32.3
CO/CO2		0.0002
CO AIR FREE		33
PRS hPA		0.00

Gene Richards  
 Customer  
PE110  
 Appliance  
325 College St #8  
 Ref.

**Benoure Plumbing & Heating, Inc. TAG# 13489**

34 Commerce Avenue  
 S. Burlington, VT 05403  
 Phone 802-864-7156  
 Fax 802-864-7167

Date of Inspection:  
7 / 13 / 11

**Heating and Venting System Documentation Form**

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 325 College St Unit # 9A

Heating System(s) Type:  
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):  
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Prestige Excellence 110

Location of Heating System: Basement

System Passed      System Failed      If System Failed, Next Appt:   /  /  

Company Conduction Inspection:  
 Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:  
 (Please Print) Ryan Benoure

Licensure for plumbing & heating?  
 Yes      No License #: PM-4086

Certification for gas equipment?  
 Yes      No Cert #: GN-2938

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: [Signature]

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

0125 1.3  
 Benoure P+H

TEST 16  
 DATE 07/13/11  
 TIME 11:00:36

COMBUSTION

FUEL	NAT	GAS
O2 %		4.4
CO2 %		9.4
CO PPM		43
FLUE °F		155.7
INLT °F		73.1
NETT °F		82.6

EFF (G)	88.0
LOSSES	12.0
XAIR %	26.7

CO/CO2 0.0004  
 CO AIR FREE 54

PRS HPA 0.00

Gene Richards  
 Customer  
PE 110  
 Appliance  
325 College #9  
 Ret.

**Benoure Plumbing & Heating, Inc. TAG# 13490**

34 Commerce Avenue  
 S. Burlington, VT 05403  
 Phone 802-864-7156  
 Fax 802-864-7167

Date of Inspection:

7 / 13 / 11

**Heating and Venting System Documentation Form**

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 325 College St

Unit # 9E

**Heating System(s) Type:**  
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

**Fuel Type:**

- Natural Gas
- Oil
- Propane

**Venting System(s):**  
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Prestige Excellence 110

Location of Heating System: Basement

System Passed

System Failed

If System Failed, Next Appt:     /    /    

Company Conduction Inspection:  
 Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:  
 (Please Print)

Ryan Benoure

Licensure for plumbing & heating?

Yes

No License #: PM-4086


Certification for gas equipment?

Yes

No Cert #: GN-2938

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector:



Comments:

C125 1-3  
 Benoure P+H

TEST 17  
 DATE 07/13/11  
 TIME 11:09:52

COMBUSTION

FUEL	NAT	GAS
O2 %		5.5
CO2 %		8.8
CO ppm		23
F LUE °F		159.1
INLT °F		73.1
NETT °F		86.0
EFF (G)		87.8
LOSSES		12.2
XAIR %		35.7
CO/CO2	0.0002	
CO AIR FREE	31	
PRS hPA	0.00	

Gene Richards  
 Customer  
PE 110  
 Appliance  
325 College # 10  
 Ref.