

Benoure Plumbing & Heating, Inc. TAG# 43154

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:
4 / 15 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards
 Address of Inspected Unit: 343 college st Unit # 1

Heating System(s) Type:
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
 (Check all that Apply)

- Direct Vent
 - B-Vent
 - Masonry *
 - Other
- *All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: w/m ultra 80
 Location of Heating System: utility Rm.

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
 (Please Print) Jeff Ryan

Licensure for plumbing & heating?
 Yes No License #: PS-163

Certification for gas equipment?
 Yes No Cert #: GB 948

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: _____

benoure.....
 #.25.....



BACHARACH, INC.
 Fyrite Insight
 SN: PX1278

Time: 11:44:52 AM
 Date: 04/15/11

Fuel
 Nat Gas

O ₂	5.0 %
CO	26 ppm
Eff	93.9 %
CO ₂	9.0 %
T-STK	113 °F
T-AIR	54.8 °F
EA	28.0 %
CO(O)	35 ppm

Comments: _____

Benoure Plumbing & Heating, Inc. TAG# 12403

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:

4 / 15 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 343 College St Unit # 2

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

**All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep*

Model # of Boiler/Furnace/Fireplace: wlm ultra 80

Location of Heating System: utility rm

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
 (Please Print) Jeff Ryan

Licensure for plumbing & heating?
 Yes No License #: PS-163

Certification for gas equipment?
 Yes No Cert #: GB-448

I have inspected the heating and venting system (s) and certify that it/is/they are installed properly and is/are operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: _____

benoure.....
 #.25.....



BACHARACH, INC.
 Fyrite Insight
 SN: PX1278

Time: 11:49:09 AM
 Date: 04/15/11

Fuel
 Nat Gas

O ₂	5.6 %
CO	17 ppm
Eff	88.1 %
CO ₂	8.6 %
T-STK	155 °F
T-AIR	57.9 °F
EA	32.6 %
CO(O)	23 ppm

Comments: _____