

Benoure Plumbing & Heating, Inc. TAG# 13144

34 Commerce Avenue
 S. Burlington, VT 05403
 Phone 802-864-7156
 Fax 802-864-7167

Date of Inspection:
4 / 13 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Gene Richards

Address of Inspected Unit: 34 Buell St Unit # _____

Heating System(s) Type:
 (Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):
 (Check all that Apply)

- Direct Vent
- B-Vent
- Masonry *
- Other

*All masonry chimneys lined or unlined
 need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: P9D20N120UPHD

Location of Heating System: Basement

System Passed System Failed If System Failed, Next Appt: / /

Company Conduction Inspection:
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:
 (Please Print) Jeff Ryan

Licensure for plumbing & heating?
 Yes No License #: PS-163

Certification for gas equipment?
 Yes No Cert #: GB-448

I have inspected the heating and venting system (s) and
 certify that it is/they are installed properly and is/are
 operating safely at this time.

Signature of Inspector: Jeff Ryan

Comments: _____

benoure.....
 #.25.....



BACHARACH, INC.
 Fyrite Insight
 SN: PX1278

Time: 09:14:18 AM
 Date: 04/13/11

Fuel
 Nat Gas

O ₂	12.8 %
CO	10 ppm
Eff	96.2 %
CO ₂	4.6 %
T-S'IK	89 °F
T-AIR	48.5 °F
EA	139.6 %
CO (0)	25 ppm

Comments: _____