

Benoure Plumbing & Heating, Inc.  
34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

TAG# 1314

Date of Inspection:  
4 / 12 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments

Jene Richard

Address of Inspected Unit: 58 Buell St

Unit # 1

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Weil McLain ~~GS~~ GV-6

Location of Heating System: Boiler room

Company Conduction Inspection:  
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:

(Please Print)

Tom Tombley

Licensure for plumbing & heating?

Yes    No License #: PM-3137

Certification for gas equipment?

Yes    No Cert #: GB-1996

OIL # OS-631

I have inspected the heating and venting system (s) and certify that it is/they are installed properly and is/are operating safely at this time.

Signature of

Inspector:

*[Signature]*

Comments:

benoure.....  
#.25.....



BACHARACH, INC.  
Fyrite Insight  
SN: PX1278

Time: 02:28:16 PM  
Date: 04/12/11

Fuel  
Nat Gas

O <sub>2</sub>	5.2 %
CO	8 ppm
Eff	87.7 %
CO <sub>2</sub>	8.9 %
T-STK	183 °F
T-AIR	71.4 °F
EA	29.6 %
CO(O)	10 ppm

Comments:

Benoure Plumbing & Heating, Inc.  
34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

TAG# 13140

Date of Inspection:  
4 / 12 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments  
Jere Richard

Address of Inspected Unit: 58 Buell St Unit # 2

Heating System(s) Type:

(Check all that Apply)

- Space Heater
- Warm Air Furnace
- Wall Mount Furnace
- Boiler
- Gas Fireplace
- Other

Fuel Type:

- Natural Gas
- Oil
- Propane

Venting System(s):

(Check all that Apply)

- Direct Vent
- B-Vent
- Masonry \*
- Other

\*All masonry chimneys lined or unlined  
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Weil mclain CGS 4  
Location of Heating System: Boiler room

Company Conduction Inspection:  
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:  
(Please Print)  
Tim Tombley

Licensure for plumbing & heating?

X Yes No License #: PM-3137

Certification for gas equipment?

X Yes No Cert #: GB-1996  
OIL # OS-631

I have inspected the heating and venting system (s) and  
certify that it is/they are installed properly and is/are  
operating safely at this time.

Signature of Inspector: [Signature]

Comments:

benoure.....  
# .25.....

BACHARACH  
BACHARACH, INC.  
Fyrite Insight  
SN: PX1278

Time: 02:29:33 PM  
Date: 04/12/11

Fuel  
Nat Gas

O <sub>2</sub>	8.8 %
CO	16 ppm
Eff	86.5 %
CO <sub>2</sub>	6.8 %
T-STK	197 °F
T-AIR	71.4 °F
EA	64.6 %
CO(0)	28 ppm

Comments:

Benoure Plumbing & Heating, Inc.

Benoure Plumbing & Heating, Inc.  
34 Commerce Avenue  
S. Burlington, VT 05403  
Phone 802-864-7156  
Fax 802-864-7167

TAG# 13139

Date of Inspection:  
4 / 12 / 11

Heating and Venting System Documentation Form

Name of Owner of Inspected Unit: Champlain Apartments  
Gene Richard

Address of Inspected Unit: 58 Buell St Unit # 3

Heating System(s) Type:  
(Check all that Apply)  
Space Heater  
Warm Air Furnace  
Wall Mount Furnace  
Boiler  
Gas Fireplace  
Other

Fuel Type:  
Natural Gas  
Oil  
Propane

Venting System(s):  
(Check all that Apply)  
Direct Vent  
B-Vent  
Masonry \*  
Other  
\*All masonry chimneys lined or unlined  
need to be inspected by qualified chimney sweep

Model # of Boiler/Furnace/Fireplace: Weil mclain GGS-4  
Location of Heating System:

Company Conduction Inspection:  
Benoure Plumbing & Heating, Inc.

Person Conducting Inspection:  
(Please Print) Tim Tronley

Licensure for plumbing & heating?  
X Yes No License #: PM-3137

Certification for gas equipment?  
X Yes No Cert #: GB-1996  
OIL # OS-631

I have inspected the heating and venting system (s) and  
certify that it is/they are installed properly and is/are  
operating safely at this time.

Signature of Inspector: [Signature]

Comments:

benoure.....  
#.25.....



BACHARACH, INC.  
Fyrite Insight  
SN: PX1278

C  
Time: 02:34:02 PM  
Date: 04/12/11

Fuel  
Nat Gas

O <sub>2</sub>	8.4 %
CO	22 ppm
Eff	85.1 %
CO <sub>2</sub>	7.1 %
T-S'IK	241 °F
T-AIR	71.6 °F
EA	59.5 %
CO(O)	37 ppm

Comments: