


# LIFE SAFETY SYSTEMS, INC.®

P.O. Box 76, Essex Jct., VT 05453-0076



PHONE 802-879-5355

FAX 802-879-4574

IN VERMONT 1-800-649-9995

FIRE ALARM SYSTEM  
Test & Inspection Report  
VERMONT PROOF OF INSPECTION STICKER # 11-09834  
SYSTEM IDENTIFICATION # F-18123

**Customer:** Richards Apartments – 361 Pearl Street

**Date:** June 3, 2011

**Contact:** Gene Richards

**Location:** 361 Pearl Street, Burlington

**Time:** Start: 11:00 End: 12:30 Total: 1:30

**Techs Sent:** SA, CB

**Panel Make & Model:** Silent Knight 5208

**Date Installed:** June 2007

	(Ah)	<u>AC Line</u>	<u>DC Charge Rate</u>	<u>Battery Voltage Under Load</u>	
				<u>DC Starting</u>	<u>DC Ending</u>
Power Supply (12)		122.6	27.3	N/A	N/A
<u>Manual Pull Stations</u>		Qty: 7	# Zones: 4	Tested: 7	
<u>Signal Horn/Strobes</u>		Qty: 5	# Zones: 1	Tested: 5	
AC Strobes		Qty: 4	# Zones: N/A	Tested: 4	
<u>Signal Horn/Strobes WP</u>		Qty: 2	# Zones: 1	Tested: 2	
Horns Only		Qty: 12	# Zones: 4	Tested: 12	
<u>Automatic Detection</u>					
Photoelectric Smokes		Qty: 5	# Zones: 4	Tested: 5	
Sprinkler Tamper		Qty: 2	# Zones: 1	Tested: 2	
Sprinkler Flow		Qty: 1	# Zones: 1	Tested: 1	
AC/DC CO Smokes		Qty: 49	# Zones: NA	Tested: 49	
System CO Detector		Qty: 1	# Zones: 1	Tested: 1	

Auxiliary Features

None


Deficiencies Found


1) None

Action Taken

1) N/A

Comments: 1) Front exit door Apt #3 is Exit of Convenience and has no pull station. 2) Replaced batteries and tested on AC power.

  
\_\_\_\_\_  
Authorized Representative  
VT State License #T1-2031

  
\_\_\_\_\_  
Reviewed by # T1-1059

cc: VT Department of Public Safety - Williston  
Burlington Fire Department - Burlington